



Appledore Marine Engineering, LLC

600 State Street, Suite E | Portsmouth New Hampshire 03801

ADDENDUM #4

Date: February 20, 2020

To: Prospective Bidders

From: Facilities Management
5765 Service Building
Orono ME 04469-5765
207-581-2638

Re: **ADDENDUM 4 to Bid Documents and Specifications for:**
DMC Pier Replacement (EDA Award Number: 01-01-14765 DMC)
University of Maine; Orono, Maine

This Addendum forms a part of the Contract Documents and modifies the original Bid Documents and Specifications dated January 24, 2020. Portions of the bid and contract documents not altered by this Addendum remain in full force.

Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidders to disqualification.

This Addendum consists of the following:

GENERAL:

1. **Contractor Question:** Spec book; 03-31-29; "Drawing and specification for the termination of cooling pipes in the mass concrete caps?"

Answer: The project specifications provide requirements for mass concrete and specific means and methods of achieving proper concrete placement and temperature control is the contractor's responsibility. Contractor's specific methods shall be submitted and approved as a construction submittal.

END OF ADDENDUM 4